WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86152
Permit No.
Basin 084

NOTICE OF INTENT NO. 38683

1. OWNER RENO-SPARKS INDIAN COLONY
MAILING ADDRESS 98 COLONY ROAD
RENO, NV 89502

ADDRESS AT WELL LOCATION WW#3
HUNGRY VALLEY, NEVADA

2. LOCATION SW ¼ SE ¼ Sec. 33 T. 22 N/S R. 20 E. WASHOE County
PERMIT NO. W-540 (Issued by Water Resources) BLM (Parcel No.) PTR-000-53 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY TOPSOIL		0	3	3
BROWN CLAY & GRAVEL	X X	3	300	297
GRAYCLAY		300	318	18
GRAY SHALE		318	500	182
PUMP BENTONITE SEAL FROM 500' TO 320'				

Date started 10-5-01, 19
Date completed 10-10-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX.	45	300	8 hrs.
TEST PUMP	107	179	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	17 Feet
9 7/8 Inches		17 Feet	500 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	-1	9 - STEEL
6 5/8	4.95	.390	-1	320 PVC

Perforations:
Type perforation MILL SLOT
Size perforation .010
From 220 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 320 feet

9. WATER LEVEL
Static water level 138 feet below land surface
Artesian flow NONE G.P.M. NONE P.S.I.
Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MILLER & SONS DRILLING (Contractor)
Address P.O. BOX 8056 (Contractor)
RENO, NV 89507

Nevada contractor's license number issued by the State Contractor's Board 037915

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418

Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date 11-5-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (01-027)