

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT N 40208

1. OWNER Anglo Gold (Serritt) Canyon Corp ADDRESS AT WELL LOCATION HC-31 Box 28 ELKO NV 89801
MAILING ADDRESS HC-31 Box 28 ELKO NV 89801 Serritt Canyon Mine
2. LOCATION NE 1/4 NW 1/4 Sec. 17 T. 40 S. R. 45 E1K0 County ELKO
PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Limstone</u>		<u>0</u>	<u>290</u>	
<u>Broken zone</u>		<u>290</u>	<u>300</u>	
<u>Limstone</u>		<u>300</u>	<u>480</u>	
	<u>100pm</u>	<u>480</u>		
<u>Broken zone</u>		<u>480</u>	<u>790</u>	
	<u>309pm</u>	<u>790</u>		
<u>Limstone</u>		<u>790</u>	<u>1000</u>	
<u>PLUGGED BY</u>				
<u>WELL LOG</u>				
<u># 112242</u>				
<u>41.361594°N</u>				
<u>115.921115°W</u>				
<u>N2027 (T2)</u>				

8. WELL CONSTRUCTION
Depth Drilled 1000 Feet Depth Cased 1000 Feet
HOLE DIAMETER (BIT SIZE)
From 8" To 0
Inches 0 Feet 1000 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>		<u>.25</u>	<u>0</u>	<u>1000</u>

Perforations:
Type perforation 510T
Size perforation 1 7/8 x 2
From 600 feet to 1000 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 540' feet below land surface
Artesian flow 40 G.P.M. P.S.I.
Water temperature _____ °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Rimrock Drilling Inc Contractor
Address 2305 East Chandler Rd ELKO NV 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0030630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1678
Signed Bruce M. Strong
By driller performing actual drilling on site or contractor
Date 1-16-02

Date started 12-27 5000
Date completed 1-2 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40 gpm</u>		