WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86207
Permit No.
Basin 72

NOTICE OF INTENT NO. 44097

1. OWNER ROAD AND HIGHWAY CONSTRUCTION
MAILING ADDRESS P.O. BOX 7084
RENO, NV 89507

ADDRESS AT WELL LOCATION RYE PATCH EXIT - INTERSTATE HIGHWAY 80

2. LOCATION ____ 1/4 ____ 1/4 Sec. 4 T 30N N/S R 33E E PERSHING County
PERMIT NO. C-207 (Issued by Water Resources) NDOT (Parcel No.) Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other ____

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PULL CASING BACK PLACE				
TRIMMIE PIPE AT BOTTOM				
AND FILLED WITH				
BENTONITE SLURRY TO				
WITH 50' OF SURFACE.				
REMOVE CASING AND				
CEMENTED 50' TO 2'				
BELOW SURFACE.				

Date started 1/28/2002 , 19__
Date completed 1/28/2002 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 147 Feet Depth Cased 147 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	147	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	147

Perforations:
Type perforation MILL SLOT
Size perforation
From 107 feet to 147 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO. (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed ____ (By driller performing actual drilling on-site or contractor)
Date 1/29/2002

USE ADDITIONAL SHEETS IF NECESSARY