COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86308
Permit No.
Basin 105

NOTICE OF INTENT NO. 42040

1. OWNER BLAIN MCGUIRE CONSTRUCTION
MAILING ADDRESS 2110 LAKESHORE BLVD
CARSON CITY, NV 89705

ADDRESS AT WELL LOCATION 1913 WISEMAN DR
GARDNERVILLE, NV 89410

2. LOCATION SE ¼ SE ¼ Sec 25 T 12 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | 1220-25-501-016 (Parcel No.) | RHUENSTROTH AREA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
COBBLES AND GRAVELS		3	20	17
GRAVELS (MED)		20	80	60
COURSE FRACTURED COBBLES		80	130	50
OBSIDIAN GRAVELS VERY FRACTURED		130	180	50
COLORED FRACTURE GRAVELS	XXX	180	200	20

RECEIVED 02 APR 17 AM 9:28 STATE ENGINEER'S OFFICE

Date started 3/20, 20 02
Date completed 3/22, 20 02

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	40	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4	Inches	0 Feet	200 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	200

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☒ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M ~~25~~ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 3/25/02

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429