

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 86323  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42036

1. OWNER KURT JOHNSON DEV. ADDRESS AT WELL LOCATION 1938 MORGAN CRT  
 MAILING ADDRESS GARDNERVILLE, NV 89410 GARDNERVILLE, NV 89410

2. LOCATION NE 1/4 NE 1/4 Sec 25 T 12 N R 20 E DOUGLAS County

PERMIT NO. 1220/25/510/014 RHUENSTROTH AREA  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
<b>HARD PAN</b>				
<b>CEMENTED GRAVELS</b>		0	8	8
<b>GRAVELS AND VOLCANIC COBBLES</b>		8	73	65
<b>COURSE VOLCANIC GRAVELS</b>		73	159	86
<b>BROWN CLAY GRAVELS</b>		159	223	64
<b>COBBLES AND GRAVELS</b>		223	265	42
<b>FRACTURED VOLCANIC GRAVELS</b>		265	295	30
<b>FRACTURED SANDY GRAVELS AND FRACTURED COBBLES</b>	<b>XXX</b>	295	340	45

8. WELL CONSTRUCTION  
 Depth Drilled 340 Feet Depth Cased 340 Feet  
**HOLE DIAMETER (BIT SIZE)**  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 3/4 Inches 0 Feet 55 Feet  
9 7/8 Inches 55 Feet 340 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

**CASING SCHEDULE**

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>+2</u>	<u>340</u>

Perforations:  
 Type perforation FACTORY MILL SLOT  
 Size perforation 3 X 3/32  
 From 320 feet to 340 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55 feet to 340 feet

9. WATER LEVEL  
 Static water level 220' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 20 P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 2/7, 20 02  
 Date completed 2/13, 20 02

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>	<u>45</u>	<u>3 HRS</u>	

Address 20 KIT KAT DRIVE  
 (CONTRACTOR)  
CARSON CITY, NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael Black  
 By driller performing actual drilling on site or contractor  
 Date 2/12/02