COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86 343
Permit No.
Basin 105

NOTICE OF INTENT NO. 42031

1. OWNER J&D CONSTRUCTION
MAILING ADDRESS MINDEN, NV 89423
ADDRESS AT WELL LOCATION 1525 PATRICK CRT
GARDNERVILLE, NV 89410

2. LOCATION NW ¼ SE ¼ Sec 32 T 13 N R 21 E DOUGLAS County

PERMIT NO. WAIVER LETTER ON FILE (Issued by Water Resources) | 1321-32-001-018 (Parcel No) | FISH SPRINGS AREA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD PAN CLAY		0	26	26
COBBLES AND CEMENTED GRAVELS		26	49	23
BROWN CLAY		49	168	119
BROWN SANDY CLAY GUMMY CLAY ZONES		168	210	42
RUSTY CLAY ZONE		210	258	48
BROWN GUMMY CLAY		258	275	17
FRACTURED GRAVELS	XXX	275	340	65

Date started 1/15, 20 02
Date completed 1/17, 20 02

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	60	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	340 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	340

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 320 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☒ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 340 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow G.P.M 25 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site drill 1905
Signed Michael L Haek
By driller performing actual drilling on site or contractor
Date 1/18/02