

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47722

1. OWNER Mike Enos ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4539 Northwind Ct. 625 Onyo Way
Sparks, Nevada 89432 Sparks, Nevada 89436
 2. LOCATION NW 1/4 Sec. 20 T. 22N N/S R. 22 E. Washoe County _____
 PERMIT NO. 076-690-42 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Cemented sand & gravels & boulders		1	10	9
Brown sandy clay		10	29	19
Soft zone (decomposed granite)		29	31	2
Brown sandy clays		31	121	90
Decomposed granite		121	135	14
Brown sandy clay		135	149	14
Soft zone (NO WATER)		149	151	2
Brown sandy clays		151	180	29
Black sandy clays		180	195	15
Soft zone	X	195	230	35
Gray sandy clays		230	237	7
Soft zone	X	237	242	5
Gray sandy clays		242	263	21
Soft zone	X	263	271	8
Gray sandy clays		271	280	9
Soft zone	X	280	290	10
Gray sandy clays		290	300	10

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 196 feet to 214 feet
 From 234 feet to 254 feet
 From 274 feet to 294 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 169 feet below land surface
 Artesian flow _____ G.P.M. 25+ P.S.I.
 Water temperature cold °F Quality clear

Date started January 31, 2002, 19_____
 Date completed February 4, 2002, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date February 6, 2002