

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47721

1. OWNER LINDA & JOE RIECHLIN ADDRESS AT WELL LOCATION 9341 N. Virginia Street
 MAILING ADDRESS 15650 Toll Road Reno, Nevada 89506
 2. LOCATION NE NW Sec 16 T 20N N/S R 19 F Washoe
 PERMIT NO. Letter Dec. 31, 2001082-650-18 Black Springs
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Boulders w/brown clay		1	3	2
Brown sandy clays		3	16	13
Brown moist clay		16	19	3
Brown sandy clays		19	40	21
Brown clay		40	51	11
Brown sandy clays with gravels		51	105	54
Brown sandy clays		105	115	10
Brown sandy clay with volcanic gravels		115	190	75
Sticky brown clays		190	205	15
Brown sandy clays with mixed gravels		205	243	38
Weathered granite with clay streaks		243	408	165
Fracture	X	408	412	4
Weathered granite with clay streaks		412	436	24
Fracture	X	436	440	4
Weathered granite with clay streaks		440	472	32

8. WELL CONSTRUCTION
 Depth Drilled 472 Feet Depth Cased 472 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 100 Feet
8 5/8 Inches 100 Feet 472 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>472</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 406 feet to 466 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 472 feet

9. WATER LEVEL
 Static water level 189 feet below land surface
 Artesian flow _____ G.P.M. 6 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date January 10, 2002

Date started January 2, 2002, 19____
 Date completed January 8, 2002, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>6</u>		