

Permits 65365-6

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 86366
Permit No. 67635 T
Basin 20 057

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45753

1. OWNER Glenn Bakker ADDRESS AT WELL LOCATION Antelope Valley, NV
MAILING ADDRESS HC61 Box 169
Battle Mountain, NV 89820 N39.969496 W117.453395 NAD83
2. LOCATION SE 14 NE 1/4 Sec. 10 T 24N N/S R 40E E Lander County
PERMIT NO. 67635-T Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other
4. PROPOSED USE Domestic Irrigation Test Monitor Municipal/Industrial Stock
5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	7	7
Gravel & Sand		7	80	73
Brown Sand		80	90	10
Gravel		90	115	25
Sand & Gravel		115	135	20
Clay W Gravel		135	195	60
Sand		195	210	15
Gravel & Sand	X	210	220	10
Sand & Clay		220	225	5
Clay W/Sand		225	248	23
Clay		248	260	12
Sand	X	260	265	5
Clay		265	270	5
Clay & Sand		270	280	10
Sand		280	284	4
Clay		284	345	61
Gravel	X	345	365	20
Clay		365	375	10

This well not drilled at this permitted location PL 15-00A

8. WELL CONSTRUCTION
Depth Drilled 375 Feet Depth Cased 375 Feet
HOLE DIAMETER (BIT SIZE)
29 Inches From 0 Feet To 375 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16</u>	<u>42</u>	<u>250</u>	<u>0</u>	<u>375</u>

Perforations:
Type perforation Mill Cut
Size perforation 1/4
From 200 feet to 375 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 50
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 50 feet to 375 feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1264 Contractor
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne
By driller performing actual drilling on-site or contractor
Date 01/02/2002

Date started 07/11/2001, 19
Date completed 07/22/2001, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.		