

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47347

1. OWNER Newmont Mining Corp ADDRESS AT WELL LOCATION TWIN CREEKS
 MAILING ADDRESS P.O. Box 69
Yucca, NV 89414
 2. LOCATION NE 1/4 NW 1/4 Sec 30 T 39 N R 43 E Humboldt County
 PERMIT NO. R-400 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Limestone		0	20	20
TUFF		20	55	35
Lime stone		55	200	205
INTRUSIVE		260	290	30
Lime Stone		290	357	67
INTRUSIVE		357	375	18
Limestone		375	500	125
INTRUSIVE		500	535	35
Lime Stone		535	545	10
INTRUSIVE		545	550	5
Lime Stone		550	560	10
TUFF		560	570	10
Limestone		570	600	30
GRAVEL PACK		600	50	
Bentonite chips		50	48	
Cement		48	0	

HOLE# VO-110

8. WELL CONSTRUCTION
 Depth Drilled 600 Feet Depth Cased 600 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
14 Inches 0 Feet 10 Feet
8 3/4 Inches 10 Feet 600 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"		3/8	+2	10
4		Sch 40	+1	600

Perforations:
 Type perforation slot
 Size perforation .020
 From SCREEN 600 feet to 60 feet
 From BLANK 60 feet to 60+1 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 600 feet to 50 feet

9. WATER LEVEL
 Static water level 98.4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started Feb 7 2002
 Date completed Feb 10 2002

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>600</u>	<u>100</u>	<u>N/A</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EKLUND Drilling Co Contractor
 Address 605 UNION PACIFIC WAY Contractor
EIKO, NV 89863
 Nevada contractor's license number 0030823
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1942
 Division of Water Resources, the on-site driller.
 Signed William Riley
 By driller performing actual drilling on site or contractor
 Date 2-10-02