

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 864017
 Permit No. 108
 Basin 108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48248

1. OWNER Pete Snook ADDRESS AT WELL LOCATION #10 Genie Drive
 MAILING ADDRESS Verdunton
 2. LOCATION NE 1/4 NW 1/4 Sec 6 T 12 N/S R 25 E Lyon County
 PERMIT NO. 12-241-17 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other well

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>3</u>	
<u>Boulders gravel</u>		<u>3</u>	<u>86</u>	
<u>Sand gravel</u>		<u>86</u>	<u>143</u>	
<u>Gravel Sand</u>		<u>143</u>	<u>160</u>	
<u>Sand Boulders</u>				

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 160 Feet
10 5/8 Inches
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.00</u>	<u>3/16</u>	<u>11</u>	<u>20</u>
<u>6 5/8</u>	<u>3.00</u>	<u>SCH 40 PW</u>	<u>20</u>	<u>160</u>

Perforations:
 Type perforation Grill Sew
 Size perforation 1/4 x 6 Lang S. Rows
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 0-50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 160 feet

Date started 5-7
 Date completed 5-8

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>Produced about 30 GPM</u>		

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling Inc Contractor
 Address P.O. Box 579 Contractor
Silver Springs NV 89929
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1377
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 5-8-08

RECEIVED
 02 JUN 20 PM 1:36
 STATE ENGINEER'S OFFICE