WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86475
Permit No.
Basin 1662

NOTICE OF INTENT NO. 22902

1. OWNER JAMES & MARY CRAIG
MAILING ADDRESS 4300 W. EMMA STREET
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 4300 W. EMA STREET

2. LOCATION NW 1/4 SE 1/4 Sec. 23 T 20S N/S R 52E E NYE County
PERMIT NO. (Issued by Water Resources) 28-812-14 (Parcel No.) CHARLESTON PARK RANCHOS (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
CLAY		0	75	75
CALICHE	WB	75	90	15
CLAY		90	107	17
CALICHE	WB	107	121	14
CLAY		121	135	14
CALICHE	WB	135	140	5

DC NR/DWR
RECEIVED
JUN 2 5 2002
LAS VEGAS OFFICE

Date started 3/13/2002 , 19__
Date completed 3/15/2002 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	3.63	.280	0	140

Perforations:
Type perforation SAW CUT
Size perforation 1/8 X 3
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. **WATER LEVEL**
Static water level 58 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dem (By driller performing actual drilling on-site or contractor)
Date 3/25/02

USE ADDITIONAL SHEETS IF NECESSARY