

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 60489
 Permit No. 64525
 Basin 08-105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37768

1. OWNER Milus Scruggs ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 340 Foothill Road 340 Foothill Road
Gardnerville Nevada Gardnerville, Nevada
 2. LOCATION NW SW 1/4 SW NW 1/4 Sec 25 T 12 N 19 E EAST Douglas County
 PERMIT NO. 19-300-60 Parcel No. 1219-36-001-002 Subdivision Name _____
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------------------|--------------|------|-----|------------|
| Brown clay w/weathered granite | X | 185 | 237 | 52 |
| Weathered Granite | | 237 | 255 | 18 |
| Weathered granite w/brown clay | | 255 | 270 | 15 |
| Weathered granite | | 270 | 370 | 100 |
| Brown clay with weathered granite | X | 370 | 420 | 50 |
| Fractured weathered granite | X | 420 | 500 | 80 |
| T.D. 500" | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 470 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 5/8 Inches 0 Feet 50 Feet
10 5/8 Inches 50 Feet 500 Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|---------------|------------|
| <u>8 5/8</u> | <u>16.92</u> | <u>.188</u> | <u>+1 1/2</u> | <u>470</u> |

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 x 3
 From 170 feet to 190 feet
 From 370 feet to 390 feet
 From 430 feet to 450 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 470 feet to 50 feet

9. WATER LEVEL
 Static water level 90' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started March 19, 1998
 Date completed April 15, 1998

7. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | | |
|---|-------------------------------|--------------|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
| <u>20+</u> | | <u>3 hrs</u> |
| | | |
| | | |
| | | |
| <u>Corrections made by L.J + T.E.</u> | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service Inc.
P.O. Box 60130
 Address _____ Contractor
Reno, Nevada 89506
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed Louis Welch
 By driller performing actual drilling on site or contractor
 Date May 12, 1998