WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

86534
OFFICE USE ONLY
Log No. 21784
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Harry Linnecke ADDRESS
Parcel 14-1019-3.27
a portion of
2. LOCATION NW ¼ ¼ Sec. 1 T. 18 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden — volanic boulders		0	52	52
Red Clay with Conglomerants of Sands - Coarse -		52	80	28
lite gray clay with multi colored sands (water bearing)		80	112	32
T.D. 112				

Date started 6-6, 1980
Date completed 6-6, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow well for 45 mins to clean & develop —			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. 10⅝ for 40' WELL CONSTRUCTION
Diameter hole 8½ inches Total depth 112 feet
Casing record 6⅝ —
Weight per foot Thickness .156

Diameter	From	To
6⅝ inches	0 feet	112 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 112 feet to 50 feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 112 feet to 92 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60' Feet below land surface
Flow G.P.M. 18+
Water temperature 62 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling + Well Service
Address 2255 Glendale Rd - Sparks NV
Nevada contractor's license number 15291
Nevada driller's license number 1132
Signed R. M. Thrall
Date 6. 9. 80

USE ADDITIONAL SHEETS IF NECESSARY

O-627