

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 86554
 Permit No. 012-B-Lemmon V.
 Basis 012-B-Lemmon V.
 NOTICE OF INTENT NO. 17991

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER DANNY RODGERS ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 11575 Heartpine
Reno, NV 89506
 2. LOCATION SE 1/4 NW 1/4 Sec. 23 T. 20N N/S R. 19 E Washoe County
 PERMIT NO. 80-363-02 Lemmon Valley
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Attempt to deepen existing well.				
Obstruction at 85 ft. NO GO.				
Top soil		0	3	3
Brown clay		3	12	9
Brown sandy clay		12	112	100
Soft zone		112	118	6
Brown sandy clay		118	165	47
Soft zone		165	170	5
Brown sandy clay		170	216	46
White sandy clay		216	224	8
Soft zone	X	224	234	10
Rusty weatered granite		234	242	6

8. WELL CONSTRUCTION
 Depth Drilled 242 Feet Depth Cased 242 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
8 5/8 Inches 0 Feet 50 Feet
6 5/8 Inches 50 Feet 242 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	242

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3" x 5" around
 From 195 feet to 235 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Ncat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 242 feet

9. WATER LEVEL
 Static water level 96 feet below land surface
 Artesian flow 23 G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor

Date started 8-7-91, 19____
 Date completed 8-8-91, 19____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date August 12, 1991