

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 86676
 Permit No. _____
 Basin Ø87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

PG 1 of 2
 NOTICE OF INTENT NO. **50853**

1. OWNER Truckee Meadows Water Authority Pah Rah Park ADDRESS AT WELL LOCATION Jerry Whitehead School,
 MAILING ADDRESS P.O. Box 30013 Sparks, NV.
Reno, NV 89520-3013

2. LOCATION NE 1/4 NW 1/4 Sec. 35 T 20N N/S R 20E E Washoe County
 PERMIT NO. 66399 Issued by Water Resources Parcel No. 030-161-13 Subdivision Name N/A

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel with sand & clay		0	52	52
Brown clay		52	83	31
Sand		83	109	26
Sand with gravel and clay		109	128	19
Andesite		128	140	12
Volcanic sediments		140	143	3
Andesite		143	154	11
Volcanic sediments		154	176	22
Blue-gray clay		176	179	3
Volcanic sediments		179	186	7
Andesite with clay		186	200	14
Blue-gray clay		200	209	9
Andesite with clay		209	214	5
Blue-gray clay		214	230	16
Clay with andesite		230	238	8
Andesite		238	240	2
Clay with andesite		240	259	19
Andesite		259	263	4
Clay with andesite		263	278	15
Blue-gray clay		278	280	2
Andesite		280	283	3
Blue-gray clay		283	318	35
Andesite		318	320	2
Blue-gray clay		320	333	13
Andesite		333	340	7
Blue-gray clay		340	358	18
Andesite		358	366	8
Blue-gray clay		366	381	15
Andesite		381	383	2
Blue-gray clay		383	398	15
Andesite		398	403	5

Continued on next page

8. WELL CONSTRUCTION
 Depth Drilled 480 Feet Depth Cased 460 Feet
 HOLE DIAMETER (BIT SIZE)
 From 25 Inches 0 Feet 50 Feet
17.5 Inches 50 Feet 480 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	78.6	0.375	0	50
12.75	43.77	0.330	+3	460

 Perforations:
 Type perforation Wire Wrap
 Size perforation 0.080"
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 480 feet

Date started 6/26/2002, 19____
 Date completed 7/10/2002, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:	
	G.P.M.	Time (Hours)
<input type="checkbox"/> Bailer	Draw Down (Feet Below Static)	
<input type="checkbox"/> Pump		
<input type="checkbox"/> Air Lift		

9. WATER LEVEL
 Static water level 36 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cool °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
 Signed John Vurgatz
 By driller performing actual drilling on-site or contractor
 Date 7/23/02

350

