

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21185

1. OWNER Don Tibbals ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2 Austin Road 2 Austin Road  
Yerington, Nevada 89447 Yerington, Nevada 89447  
 2. LOCATION NW 1/4 SE 1/4 Sec 28 T 13 N 25 E Lyon County \_\_\_\_\_  
Weed Heights  
 PERMIT NO. \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Dirt, Silt, Sand, Broken Rock</u>				
		<u>0</u>	<u>47</u>	<u>47</u>
<u>Clay, Broken Rock</u>		<u>47</u>	<u>74</u>	<u>27</u>
<u>Clay, Sand</u>		<u>74</u>	<u>82</u>	<u>8</u>
<u>Sand, Broken Rock</u>		<u>82</u>	<u>125</u>	<u>43</u>
<u>Multicolored Broken Rock, Thin Layers of Clay</u>		<u>125</u>	<u>200</u>	<u>75</u>
<u>Clay</u>		<u>200</u>	<u>252</u>	<u>52</u>
<u>Broken Rock, Clay</u>		<u>252</u>	<u>471</u>	<u>219</u>
<u>Consolidated Rock Fractured with Clay</u>		<u>471</u>	<u>480</u>	<u>9</u>

8. WELL CONSTRUCTION  
 Depth Drilled 480 Feet Depth Cased 480 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 480 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>	<u>36.71</u>	<u>.250</u>	<u>+1</u>	<u>480</u>
	<u>33.38</u>			

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From +1 feet to 138 feet blank  
 From 138 feet to 480 feet perf  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 480 feet

9. WATER LEVEL  
 Static water level 62 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 67 °F Quality cloudy

Date started August 18, 1992  
 Date completed September 4, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>250</u>	<u>145</u>	<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Sargent Irrigation Company Contractor  
 Address 9955 North Virginia Street Contractor  
Reno, Nevada 89506  
 Nevada contractor's license number issued by the State Contractor's Board 21246  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1789  
 Signed Don Tranter  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_