WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86675
Permit No.
Basin 212

NOTICE OF INTENT NO. 23363

1. OWNER CLARK COUNTY SANITATION DISTRICT
MAILING ADDRESS
ADDRESS AT WELL LOCATION PROPOSED CROSSING OF LAS VEGAS WASH AND EFFLUENT INTERCEPTOR

2. LOCATION SW 1/4 NW 1/4 Sec. 23 T. 21 N/S R. 62 E. CLARK County
PERMIT NO. (Issued by Water Resources) | Parcel No. 161-23-101-001 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL MATERIAL		0	10	10
SAND		10	15	5
CLAY		15	18	3
SAND-SILT		18	25	7
SAND		25	27.5	2.5
CALICHE		27.5	34.5	7
CLAY		34.5	68	33.5
CLAY WITH GYPSUM		68	99.4	31.4
SILTSTONE		99.4	101.5	2.1

Date started 5/8/02, 19
Date completed 5/5/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 101.5 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
42	0	101.5

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	100

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 90 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 88
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 88 feet to 101.5 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CONVERSE CONSULTANTS (Contractor)
Address 731 PILOT ROAD STE 4 (Contractor)
LAS VEGAS, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627