WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86683
Permit No.
Basin 101

1. OWNER Bob Burrows
MAILING ADDRESS 4995 Casey
NOTICE OF INTENT NO. 21111
ADDRESS AT WELL LOCATION Casey Rd.

2. LOCATION NW ¼ NW ¼ Sec. 33 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	5	5
Grey Clay		5	15	10
Brown Silt	X	15	24	9
Grey Clay	X	24	30	6
Green Sand	X	30	40	10
Black Clay		40	56	16
Green Silty Sand	X	56	130	74
Brown Clay	X	130	135	5
Grey Clay		135	140	5
Green Sand	X	140	150	10
Brown Clay		150	155	5
Brown Sand	X	155	173	18

STATE ENGINEER'S OFFICE JAN 1 7 1993

Date started Nov 28, 1992
Date completed Nov 29, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 173 Feet Depth Cased 173 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
6 Inches	50 Feet	173 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	173

Perforations:
Type perforation Machine Slot
Size perforation 50 thou
From feet to feet
From 168 feet to 172 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 59 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco (Contractor)
Address Box 888 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 172
Signed (By driller performing actual drilling on site or contractor)
Date 11-29-92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627