WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86087
Permit No.
Basin 087

NOTICE OF INTENT NO. 10080

1. OWNER Bob Farahi
MAILING ADDRESS 3840 Barker Lane Reno Nevada 89509
ADDRESS AT WELL LOCATION 5705 South Virginia St Reno Nevada

2. LOCATION NE ¼ NE ¼ Sec. 36 T. 19 N/S R. 19 E. Washoe County
PERMIT NO. Issued by Water Resources | 040-131-23 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
This was a 6" well. After looking at the well log and talking to Robert Martinez we were instructed not to pull the casing but to drill it back to bottom 65' to 108'. Then we perfed it 4 times every foot from the 108' to the top. Then we pumped neat cement 27 sack mix from the bottom up 4½ yards				

STATE ENGINEER'S OFFICE
'93 JAN 32 P2:16

Date started 1-4-1993
Date completed 1-6-1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name M & M Drilling (Contractor)
Address 2270 Pioneer Drive (Contractor)
Reno Nevada 89509
Nevada contractor's license number issued by the State Contractor's Board 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1476
Signed Steve McCay
By driller performing actual drilling on site or contractor
Date 1/18/93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627