WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86716
Permit No. 70207
Basin 212

NOTICE OF INTENT NO. 23507

1. OWNER Geo Tee
MAILING ADDRESS 4012 S. Rainbow
Las Vegas Nev 89103

ADDRESS AT WELL LOCATION 7925 Raven
Raven + Miller

2. LOCATION NE ¼ NE ¼ Sec. 21 T. 22 N/S R. 60 E. Clark County
PERMIT NO. 70207 Issued by Water Resources
17621501011 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
~~☒ Domestic~~ ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock
QM

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Cobbles - Sand Gravel		3	63	60
Cemented Gravel		63	105	42
Clay Cobbles		105	167	64
Cemented Gravel		167	410	243
Clay Gravel Boulders		410	590	180
Cemented Gravel		590	610	20
Red Clay Gravel	✓	610	650	40
Red Sand Stone	✓	650	750	100

Date started 8-19-02, 19
Date completed 8-24-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 HR

8. WELL CONSTRUCTION
Depth Drilled 750 Feet Depth Cased 750 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	750 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
F480	Pvic	6 IN.	+1	750
8 5/8		188	+18IN	5½ Ft

Perforations:
Type perforation Saw
Size perforation 1/8 X 12
From 670 feet to 750 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50+
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 750 feet to 695 feet

9. WATER LEVEL
Static water level 123 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling Contractor
Address 3955 Blue Diamond Rd. #4 Contractor
Las Vegas NV. 89139
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617
Signed [signature] By driller performing actual drilling on site or contractor
Date 8-28-02

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627