WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86739
Permit No.
Basin 212

B-10
NOTICE OF INTENT NO. 22019

1. OWNER 1195 DESERT INN ROAD, LLC
MAILING ADDRESS 1517 SEPULVEDA ~~ROAD~~ BLVD
LOS ANGELES, CA 90025

ADDRESS AT WELL LOCATION
3319 & 3337 So MARYLAND PARKWAY
LAS VEGAS, NV 89109

2. LOCATION NE ¼ NE ¼ Sec. 15 T. 21 N/S R. 61 E CLARK County
PERMIT NO. Issued by Water Resources
162-15-503-003
162-15-503-004
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	0.3	0.3
SILTY CLAY / FILL		0.3	3	2.7
CLAY WITH SILT		3	8	5
CLAY WITH CALICHE				
AND GRAVEL		8	20	12
CLAY WITH SILT		20	22	2
CLAY WITH SILT AND				
GRAVEL		22	27	5
CLAY WITH SILT		27	35	8

DO NOT WRITE
RECEIVED
SEP 2002
LAS VEGAS OFFICE

Date started 8/29/02, 19
Date completed 9/10/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	0	35

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH 40	0	35

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.10 INCH
From 5 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3.5
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 3.5 feet to 35 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CONVERSE CONSULTANTS Contractor
Address 731 PILOT ROAD STE H Contractor
LAS VEGAS, NV 89109
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627