

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23164

1. OWNER 7-11 Inc ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 10220 SW Greenburg Rd, #470 Portland Or, 97223 7291 S. Las Vegas Blvd, Las Vegas Nevada
 2. LOCATION SE 1/4 SE 1/4 Sec. 5 T. 22 N. R. 6 E. Clark County
 PERMIT NO. 23164 177-05-801-644 Parcel No. Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>08-Sm</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>5m GP</u>		<u>8</u>	<u>8 1/2</u>	<u>4.0</u>
<u>5m cl sp</u>		<u>12</u>	<u>65</u>	<u>65-53</u>
<u>cl some Gv.</u>		<u>65</u>	<u>75</u>	<u>10</u>
<u>ML Sp GP.</u>		<u>75</u>	<u>87</u>	<u>12</u>
<u>GM Sm Sp</u>		<u>87</u>	<u>91</u>	<u>4</u>
<u>5m Sp some calc chiz</u>		<u>91</u>	<u>115</u>	<u>54</u>
<u>5m Sp GP.</u>		<u>115</u>	<u>117</u>	<u>2</u>
<u>CLAY</u>		<u>117</u>	<u>160</u>	<u>13</u>

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 152 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7 7/8 Inches To 6 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>		<u>Sch 40 PVC</u>	<u>152</u>	<u>0</u>

Perforations:
 Type perforation mill slot
 Size perforation 1010
 From 152 feet to 122 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 112-80 Holeplug Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 152 feet to 112 feet

9. WATER LEVEL
 Static water level 124 feet below land surface
 Artesian flow No G.P.M. ? P.S.I. ?
 Water temperature _____ °F Quality u.k

Date started 7-16-02, 19_____
 Date completed 7-22-02, 19_____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THF Drilling Contractor
 Address 2420 S. 16 Ave Contractor
Phoenix AZ
 Nevada contractor's license number issued by the State Contractor's Board 0045849
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2145
 Signed MM
 By driller performing actual drilling on site or contractor
 Date 7-28-02