

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24113

1. OWNER Edward T. Locke
 MAILING ADDRESS 7433 Bush Garden Ave.
Las Vegas, Nev. 89129

ADDRESS AT WELL LOCATION 11470 Kyle Canyon Rd
KYLE CANYON RD.

2. LOCATION SW 1/4 SW 1/4 Sec 2 T 19S N/S R 59 E Clark County
 PERMIT NO. 126-02-401-003
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	95	
Cemented Gravel		95	160	
Brown Clay & Gravel		160	195	
Cemented Gravel		195	350	
Boulders		350	405	
Yellowish Gravel		405	450	
Cemented Gravel		450	580	
Cream Colored Gravel		580	660	
Reddish Gravel		660	740	
Cemented Gravel		740	870	
Gravel & Water	xx	870	890	
Cemented Gravel		890	950	
Gravel & Water	xx	950	975	

DO NOT WRITE
 RECEIVED
 SEP 11 2002
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 975 Feet Depth Cased 975 Feet

HOLE DIAMETER (BIT SIZE)
12 1/4 Inches From 55 To 55 Feet
9 7/8 Inches 55 Feet 975 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	50
6 1/2	SDR PVC		+1	975

Perforations:
 Type perforation Factory
 Size perforation Sieve Type .020
 From 935 feet to 955 feet
 From 895 feet to 915 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 718 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature 60.01 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick Contractor
 Address 5360 N. Bonita Vista St.
Las Vegas, Nev. 89149 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the 552
 Division of Water Resources, the on-site driller

Signed V.H. Dimick
 By driller performing actual drilling on site or contractor

Date 09-12-02

Date started 8/31/02, 19_____
 Date completed 9/12/02, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)