W 42-02-4

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 860921
Permit No.
Basin 230

NOTICE OF INTENT NO. 23127

1. OWNER Thomas Smotrich
MAILING ADDRESS 4957 Calvin Ave
Tarzana, CA 91356

ADDRESS AT WELL LOCATION
Mecca Road
Amargosa Valley, Nevada 89020

2. LOCATION NE ¼ NE ¼ Sec. 12 T. 17 N. R. 48 E. MDBM Nye County
PERMIT NO. NA Issued by Water Resources
19-731-02 Parcel No.
Mecca Estates Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil, Sand		0	4	4
Brown Sand		4	12	8
White, Caliche		12	13	1
Sandy Clay		13	25	12
Grey, Small Rock		25	32	7
Grey-White Small Rock		32	42	10
Brown, Sandy		42	52	10
Brown, Small Hard Cutting		52	62	10
Sandy		62	70	8
Sandy Clay		70	75	5
Sandy Clay		75	88	13
Hard Sandy Clay		88	92	4
Sulfur Sandy	7	92	99	7
Small Sand	16	99	115	16
Larger Sand	29	115	144	29
Hard Caliche		144	150	
Lost Circulation		150		

DCNR/DWR
RECEIVED
SEP 25 2002
LAS VEGAS OFFICE

Date started August 14 2002
Date completed August 30 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1 HP	18	—	24

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 142 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Sch 40	Contained	-2	142

Perforations:
Type perforation Saw Cut
Size perforation ⅛ x 6" x 6 Row
From 102 feet to 142 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No Minus ½ Gravel
From 50 feet to 142 feet

9. WATER LEVEL
Static water level 73 feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature Warm °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name C-D Company Contractor
Address Po Box 86 Contractor
Amargosa Valley, NV 89020
Nevada contractor's license number issued by the State Contractor's Board 0014214
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1127
Signed David C Boyer
By driller performing actual drilling on site or contractor
Date September 23, 2002

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627