WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86986
Permit No.
Basin 230

NOTICE OF INTENT NO. 81655

1. OWNER Rand Selbach
MAILING ADDRESS P.O. Box 369 Amargosa Valley, NV 89020
ADDRESS AT WELL LOCATION Tamarack Amargosa Valley, NV 89020

2. LOCATION NE ¼ NW ¼ Sec. 15 T. 16 N/S R. 48 E Nye County
PERMIT NO. N/A (Issued by Water Resources) 019-741-03 (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	55	55
Shale		55	65	10
Calcachy		65	77	12
Silty cly.		77	88	11
Limestone		88	92	4
Snd.		92	118	26
Snd + gravel	1st	118	130	12
Snd.		130	160	30
Limestone		160	165	5
gravel + snd.	2nd	165	180	15
Bottom of Well				180

DCNR/DWR
RECEIVED
AUG 22 2002
LAS VEGAS OFFICE

Date started 7/19, ~~19~~ 2002
Date completed 7/22, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12½ Inches	0 Feet	180 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC	Sch 40	0	180
Surface Protective Casing:				
8"x7'	Steel	.1808		

Perforations:
Type perforation Machined
Size perforation 3/16" x 3" Every 12"
From 120 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. (Contractor)
Address PO Box 543 (Contractor)
Amargosa Valley, NV 89020
Nevada contractor's license number issued by the State Contractor's Board 5376-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed (By driller performing actual drilling on site or contractor)
Date Aug 17, 2002

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627