WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37046
Permit No.
Basin 212

NOTICE OF INTENT NO. 23108

1. OWNER: CLARK COUNTY SCHOOL DISTRICT
MAILING ADDRESS: 4828 PEARL STREET, LAS VEGAS, NV 89121
ADDRESS AT WELL LOCATION: 1776 E. OGDEN AVE. LAS VEGAS, NV (HOLLINGWORTH ES)

2. LOCATION: DW1150 SE ¼ NE ¼ Sec. 35 T. 20 N/S R. 61 E. CLARK County
PERMIT NO. (Issued by Water Resources) | Parcel No. 139-35-710-001 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 26-30' Dewater wells | | | | |
| TOP SOIL | | 0 | 5 | |
| CALICHE | | 5 | 6 | |
| BROWN CLAY/ROCK | | 6 | 30 | |

Date started 8/21/02, 20
Date complated 9/3/02, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | 36.71 | 1.250 | 0 | 30 |
| | | | | |
| | | | | |

Perforations: Machine Perforate
Type perforation 1/4" x 2 1/2" x 3 rows @ 13
Size perforation
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed ☒ Yes ☐ No
From feet to 30 feet

9. WATER LEVEL
Static water level 11' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC. Contractor
Address 4847 S. VALLEY VIEW Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301 T-1
Signed
By driller performing actual drilling on site or contractor
Date 10/3/02

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627