

OFFICE USE ONLY  
 Log No. 87064  
 Permit No. \_\_\_\_\_  
 Basin 212 23107

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23107  
2777 PARADISE RD.

1. OWNER TURNBERRY PAVILLION PARTNERS ADDRESS AT WELL LOCATION 2777 PARADISE RD.  
 MAILING ADDRESS 2777 PARADISE RD. LAS VEGAS, NV 89109  
 2. LOCATION NE SE 9 21 61 CLARK County  
 PERMIT NO. 162-09-602-007 TOWER III  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE Dewater  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Abandon 3-10' dewater wells</u>				
<u>Well# 1</u>				
<u>No access for drilling rig</u>				
<u>Pulled casing</u>				
<u>Filled w/1.5 yards of</u>				
<u>9 sack cement slurry</u>				
<u>Well# 7</u>				
<u>Casing cemented in. 15' cut</u>				
<u>off.</u>				
<u>Filled w/1 yard of 9 sack</u>				
<u>cement slurry.</u>				
<u>Well# 8</u>				
<u>Pulled casing</u>				
<u>No access for rig</u>				
<u>Filled w/ 1.5 yard of 9 sack</u>				
<u>cement slurry.</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 40' Feet Depth Cased 40' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14</u>	<u>36.71</u>	<u>1.250</u>	<u>0</u>	<u>40</u>

Perforations:  
 Type perforation \_\_\_\_\_ **MACHINE**  
 Size perforation 1/4" x 2 1/2" x 3 rows @ 13  
 From 10 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 10/1/02 20 \_\_\_\_\_  
 Date completed 10/1/02 20 \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC. Contractor  
 Address 4847 S. VALLEY VIEW Contractor  
LAS VEGAS, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 18917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1701  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date \_\_\_\_\_