

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23107
2777 PARADISE RD.

1. OWNER TURNBERRY PAVILLION PARTNERS ADDRESS AT WELL LOCATION 2777 PARADISE RD.
 MAILING ADDRESS 2777 PARADISE RD. LAS VEGAS, NV 89109
 2. LOCATION NE SE 9 21 61 E CLARK County
162-09 602-007 TOWER III
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE Dewater
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandon 4-40' dewater wells				
Well # 5				
No access for drilling rig casing cut 20' cement to top w/1-3/4 yards 9 sack cement slurry				
Well # 6				
Pulled casing No access for rig Filled w/1-1/2 yards of 9 sack cement slurry.				
Well # 11				
Pulled casing No access for rig Filled w/ 2 yard of 9 sack cement slurry.				
Well #17 - No access for rig				
Pulled casing Filled w/1-3/4 yards of 9 sack cement slurry				

8. WELL CONSTRUCTION
 Depth Drilled 40' Feet Depth Cased 40' Feet
 HOLE DIAMETER (BIT SIZE)
 From To
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14</u>	<u>36.71</u>	<u>1.250</u>	<u>0</u>	<u>40</u>

Perforations: **MACHINE**
 Type perforation 1/4" x 2 1/2" x 3 rows @ 13
 Size perforation 10
 From 10 feet to 40 feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 10 feet to 40 feet

9. WATER LEVEL
 Static water level feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ALLEN DRILLING INC. Contractor
 Address 4947 S. VALLEY VIEW Contractor
LAS VEGAS, NV 89103

Date started 9/23/02 20
 Date completed 9/23/02 20

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Nevada contractor's license number issued by the State Contractor's Board 18917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1501
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date