WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87076
Permit No.
Basin 212

NOTICE OF INTENT NO. 211602

1. OWNER Riviera Holdings Corporation
MAILING ADDRESS 2901 S. Las Vegas Blvd
Las Vegas, NV 89109

ADDRESS AT WELL LOCATION 2901 S. Las Vegas Blvd
Las Vegas, NV 89109

2. LOCATION NW ¼ SE ¼ Sec. 09 T. 21 N/S R. 61 E/W Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 162-09-703-001 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel		0	3	3
Sandy Silt		3	15	12
Caliche		15	18	3
Sandy Silt		18	20	2
Cemented Sand+Gravel		20	22	2
Sandy Silt		22	25	3

MW-3

RECEIVED 02 JUN 23 AM 10:37 STATE ENGINEER'S OFFICE

DCNR/DWR RECEIVED OCT 1 9 2002 LAS VEGAS OFFICE

Date started June 10, 2002, 19
Date completed June 10, 2002, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 24.5 Feet

HOLE DIAMETER (BIT SIZE)
8 10.25 Inches From 0 Feet To 25 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
Schedule 40				

Perforations:
Type perforation Slotted
Size perforation 0.020
From 4.5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1.5
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3.5 feet to 25 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Badlands Drilling Corporation (Contractor)
Address 3642 N. Rancho Drive #102 (Contractor)
Las Vegas, NV 89130
Nevada contractor's license number issued by the State Contractor's Board 53311
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2216
Signed (By driller performing actual drilling on site or contractor)
Date 6-10-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627