

OFFICE USE ONLY
 Log No. 37077
 Permit No. 28828
 Basin 230

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23421

1. OWNER Bonnie Wahl ADDRESS AT WELL LOCATION 1738 E Adobe Road
 MAILING ADDRESS P.O. Box 1797 Amargosa, NV 89020
Paso Robles, Ca. 93447-1797

2. LOCATION SE 1/4 NW 1/4 Sec. 35 T. 16 S N/S R. 49 E Nye County
 PERMIT NO. 28828 19-041-29 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandstone		0	20	
Cemented gravel		20	90	
Clay with cemented gravel		90	100	
Sandstone with clay		100	115	
gravel with sandstone		115	125	
Sandstone		125	135	
gravel with clay		135	145	
Cemented gravel		145	170	
Sandstone with clay		170	290	
Clay with limestone		290	300	
Mudstone with clay		300	310	
Clay		310	350	

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)
 From To
24 Inches 0 Feet 4.0 Feet
22 Inches 4.0 Feet 35 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14</u>		<u>.250</u>	<u>+1</u>	<u>350</u>

Perforations:
 Type perforation Double saw cut
 Size perforation 3/16"
 From 80 feet to 350 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 350 feet

9. WATER LEVEL
 Static water level 120 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name American Drilling and pump Service Contractor
 Address 3040 Callahan Street Contractor
Winnemucca, NV, 89445
 Nevada contractor's license number 0020578
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1161
 Division of Water Resources, the on-site driller
 Signed [Signature]
 Date 5-13-02

Date started 4-15 2002
 Date completed 4-20 2002

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			