WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87287
Permit No. 59729
Basin ~~[illegible]~~ 230

NOTICE OF INTENT NO. 23637

1. OWNER Ponderosa Dairy
MAILING ADDRESS P.O. Box 70
Amargosa, NV 89020

ADDRESS AT WELL LOCATION G Ranch Road & Mecca Road

2. LOCATION NE ¼ NE ¼ Sec. 9 T. 17 N/S R. 49 E. Nye County

PERMIT NO. 59729 Issued by Water Resources | Parcel No. 019-381-15 | Subdivision Name
Waiver R-1168

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Air/Rotary

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well located approximately 108' from the center of Mecca Road and 156' from the center of G Ranch Road				
Well depth: 314'				
Well has severely corroded casing				
Well was perforated from 10' to 70' Six rows ¼ X 1¼ perforations See Waiver R-1168				
tremie pipe was installed to bottom of the well				
31 cubic yards of neat cement NAC 534.150 (1) were used to seal well from the bottom up				

Date started 12-19, 2002
Date completed 12-21, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 104 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name American Drilling & Pump Service (Contractor)
Address 3040 Callahan Street (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 0020578

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1161

Signed ____ by driller performing actual drilling on site or contractor
Date 12-24-02

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627