

OFFICE USE ONLY
 Log No. 87295
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22266

1. OWNER M + M SIMMONS ADDRESS AT WELL LOCATION 231 S
 MAILING ADDRESS 231 S. EMBER STREET PAHRUMP EMBER STREET PAHRUMP
 2. LOCATION SW 1/4 SW 1/4 Sec. 34 T. 20 N. R. 53 E. Nye County
 PERMIT NO. 40-701-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT		0	7	
CLAY		8	91	
GRAVELY		92	95	
CLAY WITH CALICHE STREAKS		96	175	
WATER	92			

8. WELL CONSTRUCTION
 Depth Drilled 175 Feet Depth Cased 175 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 175 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>	<u>SC 40</u>	<u>0</u>	<u>175</u>

Perforations:
 Type perforation FACTORY SET
 Size perforation .020
 From _____ feet to _____ feet
 From 175 feet to 175 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 175 feet

Date started 9-11-02
 Date completed 9-12-02

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature COLD °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GATZKE DRILLING Contractor
 Address PO Box 6678 PAHRUMP NV Contractor
 Nevada contractor's license number 36415 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1650
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 9-12-02