

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO22555

1. OWNER Wynn Las Vegas LLC ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3145 Las Vegas Blvd. South 3131 Las Vegas Blvd. South
Las Vegas, NV. 89109-1929 Las Vegas, NV. 89109

2. LOCATION NE 1/4 NW 1/4 Sec. 16 T. 21S N/S R. 61 E Clark County
 PERMIT NO. DW 1152 162-16-113-005 N/A
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other Dewatering

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cemented Calieche</u>		<u>0</u>	<u>13</u>	
<u>Brown Clay</u>		<u>13</u>	<u>15</u>	
<u>Cemented Calieche</u>		<u>15</u>	<u>16</u>	
<u>Brown Clay w/ Stringers of gravel</u>		<u>16</u>	<u>35</u>	
<u>Calieche</u>		<u>35</u>	<u>36</u>	
<u>Brown Clay</u>		<u>36</u>	<u>40</u>	

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 40
12-1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6518</u>			<u>+3</u>	<u>40</u>
<u>PVC</u>				

Perforations:
 Type perforation Screen PVC
 Size perforation _____
 From 20 feet to 40 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 15 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentanite

Gravel Packed: Yes No
 From 15 feet to 40 feet

Date started December 13, 2002 XXXX
 Date completed December 24, 2002 XXXX

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thompson Drilling Co., Inc. Contractor
 Address 7227 Hauck St. Contractor
Las Vegas, NV. 89118
 Nevada contractor's license number 4286A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2074
 Division of Water Resources, the on-site driller
 Signed Richard K. Thompson
 By driller performing actual drilling on site or contractor
 Date January 7, 2003