

OFFICE USE ONLY  
 Log No. 87317  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO22555

1. OWNER Wynn Las Vegas LLC ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3145 Las Vegas Blvd. South 3131 Las Vegas Blvd. South  
Las Vegas, NV. 89109-1929 Las Vegas, NV. 89109

2. LOCATION NE 1/4 NW 1/4 Sec. 16 T 21S N/S R 61 E Clark County  
 PERMIT NO. DW 1152 162-16-113-005 N/A  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other dewatering

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cemented Calieche</u>		<u>0</u>	<u>13</u>	
<u>Brown Clay</u>		<u>13</u>	<u>15</u>	
<u>Cemented Calieche</u>		<u>15</u>	<u>16</u>	
<u>Brown Clay w/ Stringers of gravel</u>		<u>16</u>	<u>35</u>	
<u>Calieche</u>		<u>35</u>	<u>36</u>	
<u>Brown Clay</u>		<u>36</u>	<u>40</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 40  
12-1/4 Inches Feet Feet  
 \_\_\_\_\_ Inches Feet Feet  
 \_\_\_\_\_ Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6518</u>			<u>+3</u>	<u>40</u>
<u>PVC</u>				

Perforations:  
 Type perforation Screen PVC  
 Size perforation \_\_\_\_\_  
 From 20 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 15  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Bentanite

Gravel Packed:  Yes  No  
 From 15 feet to 40 feet

9. WATER LEVEL  
 Static water level 5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started December 13, 2002 XXXX  
 Date completed December 24, 2002 XXXX

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Thompson Drilling Co., Inc. Contractor  
 Address 7227 Hauck St. Contractor  
Las Vegas, NV. 89118  
 Nevada contractor's license number 4286A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2074  
 Signed Richard K. Thompson  
 By driller performing actual drilling on site or contractor  
 Date January 7, 2003