

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23511

1. OWNER Kevin & Michelle McClary ADDRESS AT WELL LOCATION 775 WINSTON LN, INDIAN SPRINGS  
 MAILING ADDRESS P.O. Box 466 - Winston Lane Indian Springs Nev 89018-0466

2. LOCATION SW 1/4 SE 1/4 Sec. 9 T. 16 N/S R. 56 E CLARK County  
 PERMIT NO. 059-09-401-033 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay Gravel		0	50	50
Cemented Gravel	✓	60	78	18
Brown Clay		78	83	5
White Clay Gravel	✓	83	130	47
Brown Clay		130	150	20

DCNR/DWR  
 RECEIVED  
 NOV 15 2002  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 150 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6-F480 PVC</u>			<u>+1</u>	<u>150</u>
<u>6 Ft. 8 5/8 X 188</u>				

Perforations:  
 Type perforation Saw  
 Size perforation 1/8 X 12  
 From 90 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50+  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  
 Concrete Grout

Gravel Packed:  Yes  No  
 From 150 feet to 50 feet

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality good

Date started 11-4-02, 19\_\_\_\_\_  
 Date completed 11-6-02, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>		<u>2 HRS</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kedding Drilling Contractor  
 Address 3955 BLUE Diamond Rd. #4 Las Vegas Nev. 89139 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 38155  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 11-6-02