

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19155

1. OWNER Platinum Homes ADDRESS AT WELL LOCATION 2300 E Elderberry St  
 MAILING ADDRESS 2300 E Elderberry St  
Pahrump, NV 89048

2. LOCATION SE 1/4 NW 1/4 Sec. 36 T. 20 N. R. 53 E. Nye County  
 PERMIT NO. 41-055-07 Calhoun Valley Unit 2 Subdivision Name

Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
silt		0'	30'	30'
white clay		30'	40'	10'
caliche		40'	45'	5'
white clay		45'	55'	10'
caliche		55'	70'	15'
brown clay		70'	85'	15'
silt		85'	95'	10'
brown clay		95'	130'	35'
silt		130'	135'	5'
brown clay		135'	160'	25'

DCNR/DWR  
 RECEIVED  
 SEP 3 6 2002  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0	160

Perforations:  
 Type perforation saw cut  
 Size perforation 1/8" x 3"  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 6.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lake Construction Co. Contractor  
 Address 4191 S. Jackie St. Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number 0049225  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116  
 Signed Forest LaPue  
 By driller performing actual drilling on site or contractor  
 Date Feb 28, 2002

Date started Feb 11 2002  
 Date completed Feb 15 2002

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)