WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY 5 wells
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87405
Permit No.
Basin 212

NOTICE OF INTENT NO. 20275

1. OWNER Broadbent & Assoc
MAILING ADDRESS 8 W. Pacific Ave Henderson NV 89015
ADDRESS AT WELL LOCATION 333 E. Charleston Blvd. Las Vegas, NV

2. LOCATION SW ¼ SW ¼ Sec. 34 T. 20 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) 139-34-410-137 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other 175A

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	4"	4"
Type II		4"	12"	8"
Silty Sand w/gravel		12"	5	4
Caliche		5	6	1
Silty clay		6	11	5
clay w/ gravel		11	13	2
caliche		13	15	2
silty sand w/gravel		15	18	3
silty clay		18	20	2
silty sand w/gravel		20	22	2

Date started 08/13, 2003
Date completed 08/15, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 22 Feet Depth Cased 22 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	22 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.50		Sch. 40 PVC	7	22

Perforations:
Type perforation .020 Machine Slotted
Size perforation .020
From 7 feet to 22 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 4
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 22 feet to 4 feet

9. WATER LEVEL
Static water level 9 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Contaminated

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services (Contractor)
Address 7150 Placid Las Vegas NV 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193
Signed Victor Clay (By driller performing actual drilling on site or contractor)
Date 01/16/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627