

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

2 wells

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20282

1. OWNER Conoso INC ADDRESS AT WELL LOCATION 740 Mbk Blvd Las Vegas, NV
 MAILING ADDRESS 600 N. Dairy Ashford P.O. Box 2197 Houston, TX 77252-2197
 2. LOCATION NW 1/4 SE 1/4 Sec 28 T 20 N/S R 61 E Clark County
 PERMIT NO. 139-28-703-017 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Asphalt</u>		<u>0</u>	<u>4"</u>	<u>4"</u>
<u>Type II</u>		<u>4"</u>	<u>10"</u>	<u>12"</u>
<u>Sand w/gravel</u>		<u>1</u>	<u>5</u>	<u>4</u>
<u>Silty sand</u>		<u>5</u>	<u>11</u>	<u>6</u>
<u>Caliche</u>		<u>11</u>	<u>13</u>	<u>2</u>
<u>Silty sand w/clay</u>		<u>13</u>	<u>18</u>	<u>5</u>
<u>Silty sand w/gravel clay</u>		<u>18</u>	<u>21</u>	<u>3</u>
<u>clay</u>		<u>21</u>	<u>23</u>	<u>2</u>
<u>silty sand w/clay</u>		<u>23</u>	<u>25</u>	<u>2</u>

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 25 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 25 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.50</u>		<u>Sch 40 PVC</u>	<u>0</u>	<u>25</u>

Perforations:
 Type perforation Machine slot
 Size perforation .020
 From 10 feet to 25 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 8
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 8 feet to 25 feet

Date started 09/21, 2003
 Date completed 09/21, 2003

7. WELL TEST DATA 02

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature 60.1 °F Quality Contaminated Fuel

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eagle Drilling Services
 Address 7150 Placid St Las Vegas NV 89119
 Nevada contractor's license number 51266
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2193
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 01/16/03