

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

*2 wells* WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 20293

1. OWNER Michael Costanza ADDRESS AT WELL LOCATION 1132 W. Bonanza Rd. Las Vegas, NV  
 MAILING ADDRESS Route 10 Green Hills PO Box 7635 Reading, PA 19603  
 2. LOCATION NW 1/4 SE 1/4 Sec. 28 T 20 N/S R 61 E Clark County  
 PERMIT NO. 139-28-703-004 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	4"	4"
Type II		4"	82"	8"
Silty Sand w/gravel		1	7	6
Silty Clay w/gravel		7	12	5
caliche		12	14	2
silty sand w/gravel		14	17	3
silty sand		17	19	2
caliche		19	20	1
silty sand w/gravel		20	22	2
clay		22	25	3

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 25 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.50</u>		<u>Sch 40 PVC</u>	<u>0</u>	<u>25</u>

Perforations:  
 Type perforation Machine - 5/16 Hr  
 Size perforation .220  
 From 5 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 3  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 3 feet to 25 feet

9. WATER LEVEL  
 Static water level 17 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.1 °F Quality Contaminated

Date started 12/04/03 2003  
 Date completed 12/04/03 2003

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eagle Drilling Services Contractor  
 Address 2150 Placid Las Vegas, NV Contractor  
89119  
 Nevada contractor's license number issued by the State Contractor's Board 51266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193  
 Signed Victor Lho  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_