WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87422
Permit No.
Basin 212

NOTICE OF INTENT NO. 24124

1. OWNER H. Theodore Trimmer
MAILING ADDRESS 7551 N. Cimarron Rd.
Las Vegas, Nev. 89131

ADDRESS AT WELL LOCATION
Vacant SANDSTONE De CALICO

2. LOCATION NW ¼ NW ¼ Sec. 6 T. 21S N/S R. 59 E. Clark County
PERMIT NO. (Issued by Water Resources) 164-06-101-004 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	
Congiomarate		2	30	
Red Clay		30	65	
Blue Clay		65	110	
Blue Clay & Water	xx	200	210	
Hard Rock		210	235	
Blue Shale & Water	xx	235	260	
Clay		260	300	
Blue Shale & Water	xx	300	330	

DCNR/DWR
RECEIVED
JAN 2 1 2003
LAS VEGAS OFFICE

Date started 12/14/02, 19
Date completed 12/18/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 330 Feet Depth Cased 330 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	100 Feet
9 7/8 Inches		100 Feet	330 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	100
6 1/2	SRD PVC		+1	330

Perforations:
Type perforation Factory
Size perforation .032 Sieve Type
From 260 feet to 280 feet
From 300 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 88 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista St. (Contractor)
Las Vegas, Nevada 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. H. Dimick (By driller performing actual drilling on site or contractor)
Date 12-19-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627