WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY 2 wells
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87435
Permit No.
Basin 212

NOTICE OF INTENT NO. 20270

1. OWNER D. Bradley Keith (LAS Fuels c/o Southwest Airlines Co.)
MAILING ADDRESS P.O. Box 36611 1400-7FM Dallas TX 75235
ADDRESS AT WELL LOCATION McCarran Airport 5757 Wayne Newton Blvd Las Vegas NV

2. LOCATION NW ¼ NW ¼ Sec. 34 T. 21 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) 162-34-101-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	.50'	.50'
Type II		.50'	1.0'	.50'
Sand w/ Gravel		1.0	12	11
Caliche		12	14	2
Silty Clay		14	18	4
Silty Sand with gravel		18	20	2
Silty Clay w/sand		20	25	5
Clay		25	28	3
Silty Sand w/gravel		28	31	3
Caliche		31	33	2
Silty Sand w/gravel		33	40	7
Clay with gravel		40	43	3
Silty Sand w/gravel		43	46	3

Date started 11/13, 2002
Date completed 11/14, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 46 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches	0 Feet	46 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.50		Sch 40 PVC		

Perforations:
Type perforation Stainless continuous wire wrap
Size perforation .040
From 15 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 11
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 45 feet to 11 feet

9. WATER LEVEL
Static water level 28 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Contaminated Fuel

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services (Contractor)
Address 7150 Placid Las Vegas NV 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193
Signed Victor Cline (By driller performing actual drilling on site or contractor)
Date 01/08/03

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12-01) (O)-627