WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87460
Permit No.
Basin 212

NOTICE OF INTENT NO. 20280

1. OWNER AMPAC Development
MAILING ADDRESS 3770 Howard Hughes Parkway Suite 300 Las Vegas, NV 89109

ADDRESS AT WELL LOCATION SWC Gibson Rd & American Pacific Dr Las Vegas, NV

2. LOCATION NE ¼ NE ¼ Sec. 15 T. 22 N/S R. 62 E. Clark County

PERMIT NO. _____ Issued by Water Resources | 178-15-511-021 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. EW-2A LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Silty sand with gravel & cobbles		0	14	14
Dense Cemented Gravel	25	14	30	16
Brown silty, Clayey Sand	40	30	40	10
Brown silty, Clayey sand with gravel	130	40	130	110
Brown poorly graded sand with slilty clay		130	160	30
Brown sily sand with gravel weakley cemented	175	160	186	26

Date started 09/16/, 2002
Date complated 09/20, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 186 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
18 Inches	0 Feet	90 Feet
8 3/8 Inches	90 Feet	186 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.50		Sch 40 .250	0	90
4.50		Sch 80 PVC	0	180

Perforations:
Type perforation Machine Slotted
Size perforation .100
From 180 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 90
Placement Method: ☑ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 186 feet to 155 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Rocket Fuel

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eagle Drilling Services
Contractor
Address 7150 Placid Las Vegas NV 89119
Contractor

Nevada contractor's license number issued by the State Contractor's Board 51266

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193

Signed Victor Cline
By driller performing actual drilling on site or contractor

Date 09/25/02

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12-01) (O)-627