

OFFICE USE ONLY  
 Log No. 8716  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20288

1. OWNER AMPAC Development ADDRESS AT WELL LOCATION SWC Gibson Rd. American Pacific Dr. Las Vegas NV  
 MAILING ADDRESS 3770 Howard Hughes Pkwy Suite 300 Las Vegas NV 89109  
 2. LOCATION NE 1/4 NE 1/4 Sec. 15 T. 22 N/S R. 62 E. Clark County  
 PERMIT NO. 178-15-511-021 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  Air  Other \_\_\_\_\_  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sandy		25	0	25
Silt with		40		
cobbles + gravel		130		
Brown silty sand		175	25	186
+ gravel with clay				161

8. WELL CONSTRUCTION  
 Depth Drilled 186 Feet Depth Cased 181 Feet  
 HOLE DIAMETER (BIT SIZE)  

Inches	From	To	Feet
<del>8</del>			<del>186</del>
14	0	20	Feet
8 7/8	20	186	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.50		0.250	0	17
4.250		Sch 40 PVC	17	186

Perforations:  
 Type perforation Machine slotted  
 Size perforation .100  
 From 181 feet to 151 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 155  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 186 feet to 155 feet

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Rocky

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eagle Drilling Services  
 Address 7150 Placid Las Vegas NV 89119  
 Nevada contractor's license number issued by the State Contractor's Board 51266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193  
 Signed Victor Chan  
 Date 09/25/02

Date started 08/21, 2002  
 Date completed 08/27, 2002

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			