

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21230

1. OWNER NAFB ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 49 Co's 1000 Equipmental Management Nellis AFB Nev. 89191
 2. LOCATION NE NE 1/4 Sec 4 T. 20 N/S R. 62 E. Clark County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. 140-04-502-002 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel S. it + Clay		0	15	15
Silt + Clay		15	25	10
Scattered Gravel		25	30	5
Silt + clay		30	65	35
Gravel		65	70	5
Silt + clay Gravel Stragglers		70	90	20

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>12 1/4</u>	0	90		
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>	<u>Sec 80</u>	<u>30</u>	<u>90</u>
<u>6</u>		<u>.188</u>	<u>0</u>	<u>3</u>

Perforations:
 Type perforation Endless Rap Screen
 Size perforation 3/8"
 From 60 feet to 90 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 90 feet to 59 feet

9. WATER LEVEL

Static water level 69 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 47 °F Quality Bad

Date started Aug 23 2002
 Date completed Aug 23 2002

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>35</u>	<u>1 hr</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Water Development Corp. Contractor
 Address 500 Main St Woodland CA. Contractor
95695
 Nevada contractor's license number 12852 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2021T
 Signed Nick D Wells
 By driller performing actual drilling on site or contractor
 Date Aug 29 2002