

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22942

1. OWNER Patrick M. ... ADDRESS AT WELL LOCATION 2620 Western Ave Las Vegas NV 89109
 MAILING ADDRESS 2620 Western Ave Las Vegas NV 89109
 2. LOCATION NE 1/4 NW 1/4 Sec. 9 T. 21 N. R. 61 E. Clark County
 PERMIT NO. 16209-140-036 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other USA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------------|--------------|-----------|-----------|------------|
| <u>Fill (Type II)</u> | | <u>0</u> | <u>3</u> | <u>3</u> |
| <u>Silty Sand w/ gravel</u> | | <u>3</u> | <u>10</u> | <u>7</u> |
| <u>Siltstone (Brown)</u> | | <u>10</u> | <u>13</u> | <u>3</u> |
| <u>Silty Gravel w/ clay</u> | <u>1b</u> | <u>13</u> | <u>21</u> | <u>8</u> |
| <u>Gravels w/ sand</u> | | <u>21</u> | <u>25</u> | <u>4</u> |
| <u>2 wells drilled</u> | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 25 Feet
 HOLE DIAMETER (BIT SIZE)
8 1/4 Inches From 0 Feet To 25 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2.5</u> | <u>50#40</u> | <u>.28</u> | <u>0</u> | <u>25</u> |

 Perforations:
 Type perforation Machine slotted
 Size perforation 0.20
 From 15 feet to 25 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 2 feet bent 4/10/13-15' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 13 feet to 25 feet
 9. WATER LEVEL
 Static water level 16 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality Clear

Date started Sept 5 2022
 Date completed Sept 5 2022

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-------------------------------|-------------------------------|--------------|
| <u>(Table is crossed out)</u> | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Badlands Drilling Corp. Contractor
 Address 3642 N. Rancho Dr. Ste 102 Las Vegas NV. 89130 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 53311
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 2216
 Signed Jason C. ...
 By driller performing actual drilling on site or contractor
 Date 9-7-22