

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 67567  
Permit No. 227-A  
Basin

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46833  
21981

1. OWNER Nye County Dep. Natural Resources  
MAILING ADDRESS 601 Basin Rd E.  
Pharrup Nev. 89048  
ADDRESS AT WELL LOCATION NEVADA Test Site, AREA 25  
NYECO NEVADA  
2. LOCATION NW 1/4 SW 1/4 Sec. 25 T. 14 N. R. 49 E. NYECO County  
PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
0-780 silt, sands, shells cobble		0	780	
Partial Comp Picos'	Alluvial	470	780	310
NC-EWDP-22P				
0-780'				
Qal				

8. WELL CONSTRUCTION  
Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
9 5/8 Inches 357 Feet 0 Feet  
6 7/8 Inches 357 Feet 708 Feet  
5 7/8 Inches 708 Feet 780 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/4	PVC	Sch 80	520	+2
2 3/4	PVC	Sch 80	660	+2
Sumps	PVC	Sch 80	780	600

Perforations:  
Type perforation slet  
Size perforation 1.020  
From 760 feet to 660 feet #1  
From 520 feet to 520 feet #2  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 10  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 537, #1 779 feet to 508.5, #1 611 feet

9. WATER LEVEL  
Static water level 470 feet below land surface  
Artesian flow NO G.P.M. P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 1-15-02, 19\_\_\_\_\_  
Date completed 2-5-02, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
78		ATTP	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Ulev Christensen / THF Drilling Contractor  
Address 24205 16 Ave Phoenix AZ 85007 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0045849  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2182  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date 2-6-02