

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 87574
 Permit No. _____
 Basin. 212

PRINT OR TYPE ONLY
 NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22021

1. OWNER Maryland Square Shopping Center, LLC ADDRESS AT WELL LOCATION 3528 S. Maryland Parkway
 MAILING ADDRESS 777 N. Rainbow Blvd. Las Vegas NV

2. LOCATION SW 1/4 NW 1/4 Sec 14 T 21 SR 61 E County Clark

PERMIT NO. 162-14-213-002 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. (MW-8) LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0'	2.5'	2.5'
Sandy silt		2.5'	3.5'	1.0'
Caliche		3.5'	5.5'	2.0'
Sandy silt		5.5'	10.5'	5.0'
Caliche		10.5'	13.5'	3.0'
Sandy silt		13.5'	20.5'	7.0'
Caliche		20.5'	22.5'	2.0'
Silty clay		22.5'	24.5'	2.0'
Clay		24.5'	30.0'	5.5'

8. WELL CONSTRUCTION

Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>6</u> Inches	<u>0</u> Feet <u>30</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		0.308	0	30

Perforations:
 Type perforation Factory slot PVC
 Size perforation 0.020"

From 10 feet to 30 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 2 ft. Neat Cement
 Placement Method Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 8 feet to 30 feet

9. WATER LEVEL

Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATE

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Converse Consultants Contractor
 Address 731 Pilot Road, Ste. H., Las Vegas NV 89119 Contractor

Nevada contractor's license number
 Issued by the State Contractor's Board 48947
 Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller: M 1589

Signed Ronald J. Williams
 By driller performing actual drilling on-site or contractor

Date 1/29/03

Date started September 19, 2002
 Date completed September 19, 2002

7. WELL TEST DATA

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pumped <input type="checkbox"/> Air Lift			

RECEIVED
 JAN 30 2003
 LAS VEGAS OFFICE