WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87579
Permit No.
Basin 212

NOTICE OF INTENT NO. 22024

1. OWNER Becker Enterprises
MAILING ADDRESS 50 S. Jones Blvd., Ste. 100
Las Vegas NV 89107

ADDRESS AT WELL LOCATION 740 S. Decatur Blvd.
Las Vegas NV

2. LOCATION NE 1/4 SE 1/4 Sec 36 T 20 S R 60 E County Clark

PERMIT NO (Issued by Water Resources)
138-36-701-022 (Parcel No.)
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0'	2.5'	2.5'
Caliche		2.5'	5.5'	3.0'
Sand		5.5'	7.5'	2.0'
Fine sand		7.5'	8.5'	1.0'
Caliche		8.5'	12.5'	4.0'
Sandy silt		12.5'	16.5'	4.0'
Sand		16.5'	20.5'	4.0'
Sandy silt		20.5'	36.0'	15.5'

RECEIVED
JAN 30 2003
LAS VEGAS OFFICE

Date started October 15, 2002
Date completed October 15, 2002

7. WELL TEST DATA
TEST METHOD [ ] Bailer [ ] Pumped [ ] Air Lift

G.P.M	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRTUCTION
Depth Drilled 36 Feet Depth Cased 36 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	36 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		0.308	0	36

Perforations:
Type perforation Factory slot PVC
Size perforation 0.020"
From 10 feet to 36 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 2 ft.
Placement Method [ ] Pumped [X] Poured
Gravel Packed: [X] Yes [ ] No
From 8 feet to 36 feet

Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATE
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Converse Consultants (Contractor)
Address 731 Pilot Road, Ste. H., Las Vegas NV 89119 (Contractor)
Nevada contractor's license number
Issued by the State Contractor's Board 48947
Nevada driller's license number issued by the
Division of Water Resources, the on-site driller M 1589
Signed Ronald J. Mason (By driller performing actual drilling on-site or contractor)
Date 1/29/03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (0)-627