WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 82587
Permit No.
Basin 162

NOTICE OF INTENT NO. 24416

1. OWNER Gene Latour
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5831 S. Deanna St.

2. LOCATION SW ¼ SE ¼ Sec. 11 T. 21-S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-323-10 (Parcel No.) Joycelyn Estates Bk:12 Lt:2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| BrownClay | | 4 | 18 | 14 |
| BrownClay/Gran.Caliche | | 18 | 30 | 12 |
| GrayClay | | 30 | 46 | 16 |
| BrownClay | | 46 | 69 | 23 |
| GrayClay/Caliche | | 69 | 102 | 33 |
| BrownClay | X | 102 | 110 | 8 |
| Limestone | | 110 | 118 | 8 |
| BrownClay | X | 118 | 142 | 24 |
| BrownClay/Caliche | X | 142 | 160 | 18 |

RECEIVED
FEB 06 2003
LAS VEGAS OFFICE

Date started January 30, 2003
Date completed January 30, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | 4 | ¼ |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 12 Inches | 0 Feet | 160 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | 0 | 160 |
| | | | | |
| | | | | |

Perforations:
Type perforation Torch Cut
Size perforation ¼" width 8" long
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 73 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name JIM PIKE WELL DRILLING, LLC. (Contractor)
Address P.O. BOX 56 (Contractor)
PAHRUMP, NV. 89041

Nevada contractor's license number issued by the State Contractor's Board 17563A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324

Signed Jim Pike
By driller performing actual drilling on site or contractor

Date February 4, 2003

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627